

BRICK OR PRECAST ADJUSTING
RINGS AS REQUIRED TO BRING
TO GRADE. SEE DRAWING S-3.

ALL PRECAST
MANHOLE SECTIONS
TO BE ASTM C478.
CONE SECTION TO BE
CONCENTRIC UNLESS
OTHERWISE APPROVED
BY ENGINEER

SEE DRAWING S-4
FOR INVERT AND
PIPE AT WALL
DETAILS

ALL TONGUE AND GROOVE JOINTS TO BE WIPED INSIDE AND OUT WITH EMBECO CEMENT MORTAR.

WATERPROOFING AT
JOINTS FLEXIBLE
BUTYL RESIN
SEALANT. SEE
SPECIFICATIONS.

6" CRUSHED
STONE BASE

DRAWING NOT TO SCALE

MAY 27, 1994

DRAWN BY: A.H.W.F.
APPROVED BY: K.N.H.
DATE REVISED: 3/4/02 KMC

PRECAST CONCRETE MANHOLE

STANDARD
DRAWING NO.

S - 1

MURFREESBORO WATER & SEWER DEPARTMENT